



VOC/PRODUCT DATA SHEET

Date:	September 13, 2006
Vendor Name:	Novaflex Group
Vendor Address:	20 East Pearce Street, Richmond Hill, ON L4B 1B7
Contact:	
Telephone:	905-731-9411
Product Name/Number:	Ductbond Duct Sealant
VOC (weight % as supplied)*:	1.3541 %
VOC (grams/liter as supplied):	19 g/l
VOC (grams/liter less water):	27.5 g/l
Solids (weight %):	69 %
Product Specific Gravity (ASTM D-1475):	1.4
Product Weight per Gallon (ASTM D-792):	11.7 lbs/gal

**Ductbond Water Based Duct Sealant meets the requirements of LEED Certification:
Indoor Environmental Quality- Credit 4.1 (Low-Emitting Materials: Adhesives and Sealants)**

Requirements: The VOC content of adhesives and sealants used must be less than the current VOC content limits of South Coast Air Quality Management District (SCAQMD) Rule #1168, AND all sealants used as fillers must meet or exceed the requirements of the Bay Area Air Quality Management District Regulation 8, Rule 51.

South Coast Air Quality Management District (SCAQMD) Rule #1168
Bay Area Air Quality Management District Regulation 8, Rule 51

Sealants:

Architectural: 250 g/l, less water and exempts

Other: 420 g/l, less water and exempts

*The VOC information presented here is calculated based on the theoretical VOC contribution of each ingredient in each formulation. The VOC information for each ingredient is either measured using EPA Method 24 (40 CFR 60 Appendix A), or per composition data as reported to us by the supplier (40 CFR 63.827(b)).