

Z-VENT[®] Suggested Resistance Loss Coefficients or K-Values



Z-VENT Suggested Resistance Loss Coefficients or K-Values*	
Component	Suggested K-Value
Tee	1.25
Boot Tee	0.75
Cap Low Resistance	0.50
90° Elbow	0.75
45° Elbow	0.30

***From Table 9 in Chapter 35 of 2016 ASHRAE Handbook - HVAC Systems & Equipment**

Z-VENT™ is manufactured by Z-Flex® US, a Novaflex Group Company

Canada: 452 Attwell Drive, Etobicoke, ON M9W 5C3 tel: 416.679.0045 • fax: 416.679.0051
USA: 20 Commerce Park North, Bedford, New Hampshire tel: 603.669.5136 800.654.5600 • fax: 603.669.0309