

According to Section 503.4.1: Plastic piping in Chapter 5: Chimney and Vents of NYC Fuel Gas Code, PVC shall not be permitted to vent appliance see following excerpt or visit link to code.

http://www.nyc.gov/html/dob/apps/pdf_viewer/viewer.html?file=2014CC_FGC_Chapter5_Chimneys_and_Vents.pdf§ion=conscode_2014

503.4.1 Plastic piping. Plastic piping used for venting appliances listed for use with such venting materials shall be listed and installed in accordance with the terms of its listing and the manufacturers' instructions. Installation shall be in accordance with the *New York City Building Code*. PVC shall not be permitted.

U.S.A.

20 Commerce Park North, Bedford, NH 03110-6911
Tel: 603.669.5136 Fax: 888.889.3539 Toll Free: 800.654.5600

CANADA

452 Attwell Drive, Etobicoke, ON M9W 5C3
Tel: 416.679.0045 Fax: 416.679.0051